



Sample Engineering Specifications

EverTuff® CPVC Schedule 40 & 80 Pipe & Fittings

EverTuff® CPVC Schedule 40 & 80 Pipe & Fittings Specification for Marine

Spears® EverTUFF® CPVC Schedule 40 and Schedule 80 pipe shall be manufactured by Spears® Manufacturing Company from a Type IV, Grade I Chlorinated Polyvinyl Chloride (CPVC) compound with a Cell Classification of 23447 per ASTM D1784. The pipe shall be manufactured in strict compliance to ASTM F441, consistently meeting the quality assurance test requirements of this standard. All Spears® EverTUFF® pipe shall be manufactured in the USA immediately wrapped for protection. The pipe shall be provided with plain ends in 20 foot cut lengths. All Spears® Evertuff® pipe shall be certified by NSF International for potable water applications and marked accordingly.

All EverTUFF® CPVC 40 and Schedule 80 pipe shall be approved by the United States Coast Guard, meet the low flame spread requirements and smoke and toxicity requirements of the 2010 FTP Code Annex 1. Parts 2 and 5, and may be installed in accommodation, service and control spaces without meeting the additional requirements of 46 CFR 56.60-25(a) (2) as manufactured by Spears® Manufacturing Company. All EverTUFF® CPVC Schedule 40 and Schedule 80 pipe shall be approved by the American Bureau of Shipping (ABS) and meet IMO FTP Code Annex 1, Part 5 for Surface Flammability (IMO Resolution A.653 (16) for Low Flame Spread) with a Limited Lifetime Warranty as manufactured by Spears® Manufacturing Company.